

Well No 30/3-29F01

October 1, 1966

Mr. Ray Jacobson  
6100 Roosevelt Way No. East  
Seattle, Washington

Well Log---Panarama Vista

0	-	79	Sand and 5% gravel
79	-	90	Blue silt
90	-	119	Blue silt
119	-	153	Brown sand
153	-	181	Brown sand and 10% clay
181	-	193	Blue clay
193	-	214	Brown silt
214	-	243	Fine brown sand
243	-	250	Grey sand, fine, water in small amount
250	-	266	Coarser sand
266	-	291	Water in coarse sand

Total depth of well, 291'

Installed 15' of Johnson Everdur, 8"

5' of #12 slot

10' of #10 slot

4" baildown fitting with figure K packer

7' of 6" pipe on top of screen

Static Water Level, 245'

Pumped 30 G.P.M. with 4 hours continuous pumping

(over)

